

Authority            Quality Manager  
Document            TCISEXEDTA  
Revision             F  
Date                 26/11/09  
Signed

## Temperature Controls Pty Ltd

ABN 966 501 901 83

7 Yamma St

Sefton NSW 2162      Phone 612 9721 8650      Fax 612 9738 9339

Ex de Ex tD A21 Certified Fixed Temperature Probe Assembly

Installation Instructions for Model TC20FIXTA

This Temperature Probe Assembly carries Test Safe, Increased Safety, Flameproof or Protection by Enclosure tD in Combustible dust Certification in Hazardous Areas.

Ex de IIC T6 IP66 or Ex tD A21 T6 IP66 Certificate No IECEX TSA 09.0045X

1. Only approved components shall be connected to this temperature assembly.
2. Check that O ring is correctly fitted to ensure sealing integrity is maintained.
3. Maximum Voltage and power not to exceed Certificate of Conformity approval 40 Volt 3 Watt
4. Ensure all wiring insulation and connections are correct and undamaged.
5. Check earthing connections are tight and corrosion free. Note: Internal earth bonding point is located under terminal block and should be connected prior to fitting / wiring terminal block.
6. Ensure cap is secure and locking screw tight.
7. Are there any obvious signs of unauthorised modifications or additions that invalidate certification?
8. Any fixed Ex ed assembly shall be adequately guarded to protect it from impact damage when installed
9. Any fixed Ex ed assembly shall have a support mechanism in place to ensure the terminal head is adequately supported to prevent damage to the mims element cable.
10. There are no serviceable parts for this temperature assembly, for repair or replacement contact the manufacturer.
11. The T temperature rating applied to the temperature assembly is the maximum surface temperature the sensor shall be subjected to. If the temperature sensor is connected to an approved enclosure suitable lagging extensions as per Drawing 6682 shall be used to ensure the enclosure does not exceed its T6 rating.

This document shall be supplied with any Ex ed Temperature assembly supplied to a customer.

Certification Officer

Phillip Lonsdale Email [p.lonsdale@temperature.com.au](mailto:p.lonsdale@temperature.com.au)

November 2009

Page 1 of 1