


Ex de/ Ex tD Certified Temperature Assembly Fixed Nipple Connection

MODEL No: TC20FIXTA

MATERIAL: ALUMINIUM ALLOY
 DEGREE OF PROTECTION : IP66

SS L BRACKET WITH 2 MOUNTING HOLES



CERTIFIED FOR USE WITH MIMS THERMOCOUPLE & MIMS RTD SENSOR

MAX 40 V 3 WATT RATING ACCEPTS 33 MM & 40 MM CENTRE TERMINAL BLOCKS OR IN HEAD TRANSMITTERS.

IECEX Certificate of Conformance No : IECEX TSA 09.0045X
 for complete assembly

IECEX Certified or T6 IP66 or Ex tD A21 T6 IP66

MIMS SENSOR SURFACE MOUNT
 IECEX CERTIFIED TERMINAL HEAD
 SKIN TEMPERATURE SENSOR

TEMPERATURE CONTROLS PTY LTD		QUALITY ENDORSED COMPANY Certificate No: QES 14412 AS/NZS 9001:2008
<p>CONDITIONS</p> <p>THIS DRAWING IS OUR EXCLUSIVE PROPERTY AND MUST NOT BE COPIED OR HANDED TO ANY OTHER PARTIES WITH OUT WRITTEN PERMISSION. IT SHALL BE RETURNED UPON REQUEST</p>		
<p>SYDNEY: 7 YAMMA ST SEFTON , NSW 2162 PHONE: (02) 9721 8644 FAX : (02) 9738 9339 MELBOURNE: 8/280 Whitehall St YARRAVILLE, VIC 3013 PHONE: (03) 9687 0000 FAX : (03) 9687 1900 BRISBANE: 28A/125 Kerry Road, Archerfield Qld 4108 PHONE: 0418 222 968 EMAIL: sales@temperature.com.au</p>		
<p>TITLE Ex de / Ex tD ASSEMBLY</p>		
SIZE : A4	DATE : 11/12/13	DWG NO : SD580
SCALE : NTS	DRAWING BY R.B	REV : 07