


Ex de / Ex tD Certified Temperature Element Fixed Nipple Connection
 MODEL No: TCFIXEX
 Dual Certified Ex d Flameproof & Ex e Increased Safety




SUITABLE FOR USE WITH CERTIFIED Ex d / Ex e / Ex tD ENCLOSURE OR TRANSMITTER HOUSING WHICH HAS 1/2" NPT OR M20 X 1.5 MM PROCESS CONNECTION

CERTIFIED FOR USE WITH MIMS THERMOCOUPLES AND MIMS RTD SENSORS

FOR APPLICATIONS WHERE THE TEMPERATURE SENSOR IS TO BE USED IN T5 TO T1 TEMPERATURES A 50 MM LAGGING EXTENSION SHALL BE FITTED TO ENSURE THE ENCLOSURE REMAINS BELOW T6 TEMPERATURE RATING.

IECEX Dual certified Ex de IIC T6 IP66 or Ex tD A21 T6 IP66

IECEX Certificate of Conformance No : IECEX TSA 09.0044U
 as a component.

| | | | |
|--|--|--|---|
| TEMPERATURE CONTROLS PTY LTD | | Certificate No: QEC 14412 ISO 9001:2008 | |
| CONDITIONS THIS DRAWING IS OUR EXCLUSIVE PROPERTY AND MUST NOT BE COPIED OR HANDED TO ANY OTHER PARTIES WITH OUT WRITTEN PERMISSION. IT SHALL BE RETURNED UPON REQUEST | SYDNEY : 7 YAMMA ST SEFTON , NSW 2162 PHONE : (02) 9721 8644 FAX : (02) 9738 9339 | |  Quality Endorsed Company |
| | MELBOURNE : 8 / 280 WHITEHALL ST YARRAVILLE VIC 3013 PHONE : (03) 9687 00 FAX : (03) 9687 1900 EMAIL : sales@temperature.com.au | | |
| | TITLE Ex de / Ex tD ELEMENT | | |
| | SIZE : A4 | DATE : 27/06/11 | |
| SCALE : NTS | DRAWING BY R.B | REV : 02 | |