

[1] **EC-TYPE EXAMINATION CERTIFICATE**



[2] **Equipment or Protective System intended for use
in Potentially Explosive Atmospheres
Directive 94/9/EC**

[3] EC-Type Examination Certificate Number: DEMKO 03 ATEX 134077X

[4] Equipment: 2-wire Transmitter, MESO-HX

[5] Manufacturer: Inor Process AB

[6] Address: Box 9125, SE-200 39 Malmö, Sweden

[7] This equipment or protective system and any acceptable variation there to is specified in the schedule to this certificate and the documents therein referred to.

[8] UL International Demko A/S, notified body number 0539 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. 134077

[9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
EN 50014: 1997 E incl. A1+A2 EN 50020: 2002 E EN 50284: 1999 E

[10] If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.


[11] This EC-Type examination certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by the certificate.

[12] The marking of the equipment or protective system shall include the following:

Ex II 1G EEx ia IIC T4/T5/T6

On behalf of UL International Demko A/S

Herlev, 2003-03-17


Karina Christiansen
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500

Certificate: 03 ATEX 134077X

This certificate may only be reproduced in its
entirety and without any change, schedule included



An Affiliate of
**Underwriters
Laboratories Inc.®**

Schedule

[13]

EC-TYPE EXAMINATION CERTIFICATE No. DEMKO 03 ATEX 134077X

[14]

[15] Description of Equipment or protective system

Meso-HX is an isolated two wire transmitter intended for temperature measurement in process industri. The input signal is either of resistance or voltage type (E.g Thermocouples, Pt100, Pt1000 (up to 2000 ohm) and mv-inputs between -1V to +1V). The transmitter is calibrated and configured with a PC, through the output. The transmitter is intended to be mounted in hazardous area and is powered with an intrinsic safe power supply unit, which is mounted outside the hazardous area.

Temperature range

Ambient temperature range

-40 °C to +85 °C

-40 °C to +65 °C

-40 °C to +50 °C

Temperature class

T4

T5

T6

Electrical data

Intrinsically safe specifications:

The equipment must be electrically connected (terminal 5 and 6) via an certified isolating interface/ zener barrier having double or reinforced insulation and shall placed outside the hazardous area.

U_i : 30 V

I_i : 100 mA

P_i : 0,9 W

L_i : 1 mH

C_i : 1 nF

The terminals 1,2,3 and 4 of the transmitter may only be connected to transducers complying with 'Simple Apparatus' according to EN 50020 § 5.4.

[16] Report No.

Project Report No.: 134077-01

The scheduled drawings are listed in the document S-9063 date 2003-03-14 Rev C entitled "List of scheduled and related drawings"

[17] Special conditions for safe use:

- The equipment must be electrically connected via an certified isolating interface/ zener barrier having double or reinforced insulation and shall placed outside the hazardous area.

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500

Certificate: 03 ATEX 134077X
Report: 134077-01

This certificate may only be reproduced in its
entirety and without any change, schedule included



An Affiliate of
**Underwriters
Laboratories Inc.®**

P2/3

Schedule

EC-TYPE EXAMINATION CERTIFICATE No. DEMKO 03 ATEX 134077X

- The transmitter is calibrated and configured with a PC, which can be connected to the transmitter output (terminal 5 and 6). When programming the transmitter by PC and communication interface the intrinsically safe data shall be observed.
- The apparatus must be installed in an enclosure having an Ingress Protection for the actual use and with an Ingress Protection of at least IP20.
The requirement from EN50284 § 4.4.3 (The chargeable non-conductive surface or its projection shall be limited to 4 cm² for apparatus of Group IIC) is not fulfilled. When mounted in Ex-compatible enclosures, such as junction boxes or DIN Standard Head, the requirements is fulfilled.

18] Essential Health and Safety Requirements

Concerning ESR this Schedule verifies compliance with the Ex standards only. The manufacturer's Declaration of Conformity declares compliance with other relevant Directives.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in ANNEX III to Directive 94/9/EC of the European Parliament and the Council of 23 March 1994.

On behalf of UL International Demko A/S

Herlev, 2003-03-17

Karina Christiansen
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565
Fax: +45 44856500

Certificate: 03 ATEX 134077X
Report: 134077-01

This certificate may only be reproduced in its
entirety and without any change, schedule included



An Affiliate of
**Underwriters
Laboratories Inc.**

P3/3