



# Ex de Flame Proof / Ex tD Dust Certified Temperature Assembly Fixed Nipple Connection MODEL No: TC20FIXTA

MATERIAL:  
ALUMINIUM ALLOY  
DEGREE OF PROTECTION : IP66

SS L BRACKET WITH 2 MOUNTING HOLES



2mm THICK  
HOLES ARE 9.5mm DIA,  
10.25mm FROM BOTTOM AND TOP EDGES  
= CENTRE OF HOLE  
8.25mm FROM SIDE EDGE  
= CENTRE OF HOLE

CERTIFIED AS MIMS THERMOCOUPLE & MIMS RTD SENSOR

MAX 40 V 3 WATT RATING ACCEPTS 33 MM & 40 MM CENTRE TERMINAL BLOCKS  
OR IN HEAD TRANSMITTERS.

IECEX certified Ex de IIC T6 IP66 or Ex tD A21 T6 IP66

IECEX Certificate of Conformance No : IECEX TSA 09.0045X  
for complete assembly

MIMS SENSOR SURFACE MOUNT  
IECEX CERTIFIED ASSEMBLY

|   |                |                          |  |
|---|----------------|--------------------------|--|
| <b>TEMPERATURE CONTROLS PTY LTD</b>   |                |                          | QUALITY ENDORSED COMPANY<br>Certificate No: QEC 14412<br>AS/NZS 9001:2008  |
| <b>CONDITIONS</b>   |                |                          | SYDNEY: 7 YAMMA ST SEFTON , NSW 2162<br>PHONE: (02) 9721 8644 FAX : (02) 9738 9339<br>MELBOURNE: 8/280 Whitehall St YARRAVILLE, VIC 3013<br>PHONE: (03) 9687 0000 FAX : (03) 9687 1900<br>BRISBANE: 28A/125 Kerry Road, Archerfield Qld 4108<br>PHONE: 0418 222 968<br>EMAIL: sales@temperature.com.au |
| THIS DRAWING IS OUR EXCLUSIVE PROPERTY AND MUST NOT BE COPIED OR HANDED TO ANY OTHER PARTIES WITH OUT WRITTEN PERMISSION. IT SHALL BE RETURNED UPON REQUEST |                |                          | TITLE<br><b>Ex de / Ex tD ASSEMBLY</b>   |
| SIZE : A4   | DATE :11/12/13 | <b>DWG NO : SD 582CF</b> |  |
| SCALE : NTS   | DRAWING BY R.B | <b>REV : 01</b>          |  |